

REV	DATE	DESCRIPTION
0	20-06-23	ISSUED FOR CONSTRUCTION
1	24-08-23	ACCESS CONTROL ADDED FOR STORE ROOMS
2	28-11-23	AS BUILT DRAWING
3	08-09-24	AS BUILT DRAWING - RISERS

LEGEND	NOTES
	1. ALL CONDUIT WORK SHALL BE BOSAL.
	2. 25mm BOSAL CONDUIT FIXED TO SLAB MUST BE SADDLED @ INTERVALS OF NOT MORE THAN 1000mm.
	3. ALL CONDUITS TO BE FITTED WITH DRAW WIRE.
	4. 70mm/70mm GALVANIZED TRUNKING IN CABLE TRAY SYSTEM TO BE USED FOR FIRE SYSTEM WIRING ONLY.
	5. LINE RELAYS TO MONITOR DOOR CONTACTS ON FIRE ESCAPE DOORS TO BE MOUNTED ON CABLE TRAY CLOSEST TO FIRE DOOR.
	6. EVERY 20th ADDRESSABLE DEVICE SHALL BE A LINE ISOLATOR.
	7. EVERY ACCESS CONTROLLED DOOR SHALL HAVE THE CORRESPONDING DOOR CONTROLLER INSTALLED IN THE CEILING VOID AND SHALL BE COUPLED TO ITS RESPECTIVE CARD READER OR BIOMETRIC READER DOOR KIT.
	8. PLEASE MAKE USE OF DEDICATED POWER POINTS IN CEILING VOID TO POWER UP ACCESS DOOR CONTROLLER KIT.
	9. ALL ACCESS CONTROL, CARD READERS, "NO TOUCH" EXIT SENSORS, GREEN BREAK GLASS UNITS, FIRE DETECTION RED BREAK GLASS UNITS TO BE AT 1400mm TO CENTER OF DEVICES FROM F.F.
	10. REFER TO DWG. NO.2322/00- FOR DETAIL ILLUSTRATIONS OF THE ELECTRONIC INSTALLATION.

AS BUILT
DRAWING


REV	DATE	DESCRIPTION
0	20-06-23	ISSUED FOR CONSTRUCTION
1	24-08-23	ACCESS CONTROL ADDED FOR STORE ROOMS
2	28-11-23	AS BUILT DRAWING
3	08-09-24	AS BUILT DRAWING - RISERS



public works
& infrastructure
Department:
Public Works and Infrastructure
REPUBLIC OF SOUTH AFRICA



DESIGN CONSULTANT :



G&J CONSULTING ENGINEERS
398 Albert Road
Sullivanville
7925
tel: +27 87821 7179
email: admin@gjact.co.za

CLIENT

PARLIAMENT
CAPE TOWN
90 PLAIN STREET

PROJECT TITLE

109_WP A.3 - TEMPORARY OFFICES
FOR MEMBERS 4TH & 5TH FLR_90
PLEIN STREET

DRAWING TITLE

FOURTH FLOOR
ACCESS CONTROL & CCTV LAYOUT

SCALE

1:100

DESIGNED

N.T.T

ECISA Reg No.

9270072

DRAWN

Y. F.

SIGNATURE

ONILET

CHECKED BY

Onilelet Tavema-Turisan

PROJECT NO.

2322

DRAWING NO.

EE.1

REV. 4